



## Intumescent Coatings for advanced Passive Fire Protection

Erik van Schaijk  
Research Engineer  
Group R&D – Fire Protection  
Hempel A/S

# Content

- Fire protection by intumescent coatings
- Specification principles
- Development and testing of intumescent products
- Global approvals
- Reliability and durability of intumescent coatings
- Approval of paint systems for fire protection



# Introduction to fire & fire protection





**HEMPEL**

# Types of fires

There are 3 main types of fire

## Cellulosic fires

- Occur when burning wood, textiles and paper etc.
- Civil construction

## Hydrocarbon fires

- Occur when burning oil or gas
- O&G or petrochemical industry

## Jet fires


- Occur when burning compressed oil and gas
- O&G or petrochemical industry



# Types of fires

Temperature development of different fire types

- Cellulosic fires
  - ISO 834
  - $T = 20 + 345 * \log(8 * t + 1)$
- Hydrocarbon fires
  - UL1709/BS476
  - $T = 20 + 1080 * (1 - 0.325 * e^{-0.167 * t} - 0.675 * e^{-2.5 * t})$
- Jet fires
  - ISO 22899
  - Estimated temperature curve



# Jet Fire Resistance (ISO22899-1)

- 1500x1500mm 10mm thick steel box with 250mm deep, 20mm thick flange (~500kg)
- Jet impinges on flange 375mm from base
  - 0,3kg/s<sup>-1</sup> ±0,05 kg propane
  - 260m/s<sup>-1</sup> velocity at impact area
- First thermocouple to 400°C = FAILURE!
  - Requires Epoxy intumescents



# Active and passive fire protection

Fire protection of steel can be done with two methods:

## Active fire protection

- Methods that require a certain amount of motion and response in order to react to put out the fire
- E.g. sprinkler systems, fire extinguisher systems

## Passive fire protection

- Methods that contain, minimize the impact, or slow the spread of the fire
- Contrary to active fire protection, the passive type does not need a response before reacting to the fire
- E.g. intumescent coatings, boards, fire walls, foams





# Cellulosic and Hydrocarbon intumescent

Cellulosic Intumescent	Hydrocarbon & Jet Fire Intumescent
Also called <b>Thin film intumescent</b>	Also called <b>Thick film intumescent</b>
Normally Acrylic based	Normally Epoxy based
Water or solvent based	Solvent free
1 component	2 component
Application by Airless Spray	Application by Plural Component Spray followed by trowelling
White	Grey/Blue/Beige
~0.2–5 mm dry film thickness	~2-40 mm dry film thickness
~40-60x expansion	~4-10x expansion



# Normal airless and Plural Component spray equipment





# Intumescent coatings for cellulosic fires

# Basic concept of intumescent


- Intumescent is a substance which swells as a result of heat exposure, thus increasing in volume, and decreasing in density.
- Expansion is normally around 40-60 times the applied DFT
- Char of low thermal conductivity that reduces heat transfer to substrate
- Thermal insulation of substrate





# Reactions during intumescence


- Softening of binder (**Acrylic resin**)
- **Acid catalyst** (Ammonium polyphosphate)



- **Carbon source** (Pentaerithritol)



- **Blowing agent** (Melamine)







# Specification of fire protective coatings



# Specification principles

Specifications of thickness of intumescent vary depending on the substrate and steel profile

- Factors influencing the specification
  - Type of section (open/ closed/cellular profile)
  - Massivity of the steel ( $H_p/A$ )
  - Exposure (i.e. 3 sided, 4 sided exposure)
  - Fire Rating FR (30/ 60/ 90/ 120 min)
  - Critical temperature (CT)



# H<sub>p</sub>/A concept

## High H<sub>p</sub>/A value

- Low mass of steel
- Fast heating
- Higher dry film thickness of intumescent

## Low H<sub>p</sub>/A value


- High mass of steel
- Slow heating
- Lower dry film thickness of intumescent



# Hp/A concept


## Hp/A factor

- Synonyms:  $A/V$  ; Massivity ; Section Factor
- Hp/A is a calculated numerical value [m-1]
- Hp = Heated Perimeter of the steel [m]
- A = Cross-sectional Area of the steel [m<sup>2</sup>]



# Hp/A calculation

## 4 side-exposure



$$H_p = 1,140 \text{ m}$$


$$A = 53,80 \text{ cm}^2$$

$$H_p = 1,140 \text{ m} = 1,140 \text{ m}$$

$$A = 53,80 \text{ cm}^2 = 0,00538 \text{ m}^2$$

$$H_p/A = 212 \text{ m}^{-1}$$

## 3 side-exposure



$$H_p = 0,940 \text{ m}$$

$$A = 53,80 \text{ cm}^2$$

$$H_p = 0,940 \text{ m} = 0,940 \text{ m}$$

$$A = 53,80 \text{ cm}^2 = 0,00538 \text{ m}^2$$

$$H_p/A = 175 \text{ m}^{-1}$$



**HEMPEL**

# Loading tables – 4 sided Columns

**Table 11** Required thickness of HEMPACORE ONE 43600 or HEMPACORE ONE FD 43601 (mm) for a fire resistance period of 120 minutes

Section factor (m <sup>-1</sup> )	Design temperature (°C)								
	350	400	450	500	550	600	650	700	750
70	-	-	3.146	2.248	1.740	1.175	1.094	0.994	0.811
75	-	-	3.243	2.360	1.852	1.277	1.174	1.072	0.883
80	-	-	3.340	2.471	1.965	1.379	1.253	1.149	0.955
85	-	-	3.436	2.583	2.078	1.481	1.333	1.227	1.028
90	-	-	3.533	2.694	2.190	1.583	1.413	1.304	1.100
95	-	-	3.630	2.806	2.303	1.685	1.493	1.382	1.172
100	-	-	3.727	2.917	2.416	1.787	1.572	1.459	1.244
105	-	-	3.823	3.029	2.525	1.889	1.652	1.537	1.316
110	-	-	3.955	3.140	2.632	1.992	1.732	1.614	1.389
115	-	-	4.100	3.251	2.740	2.094	1.812	1.692	1.461
120	-	-	4.245	3.363	2.847	2.196	1.891	1.769	1.533
125	-	-	4.390	3.474	2.955	2.298	1.971	1.847	1.605
130	-	-	4.535	3.586	3.062	2.400	2.051	1.924	1.678
135	-	-	4.680	3.697				2.002	1.750
140	-	-	4.825	3.809				2.079	1.822
145	-	-	4.971	3.940				2.157	1.894
150	-	-	5.116	4.082	3.492	2.873	2.370	2.234	1.966
155	-	-	5.261	4.224	3.599	2.994	2.449	2.312	2.039

R90 (550°C): 1.360 mm



# Hempel's R&D Fire Protection

# Focussed investment to support Hempel's growth plans

- Increasing legislation in fire protection
- Intumescent coatings are essential part of the protection system
- In the past, Hempel has had licensing agreements with other manufacturers
- The development of our own products is part of the growth strategy in Industrial protection
- State-of-the art facilities
- Highly qualified experts




*HEMPEL IR&D Centre in Polinya, Barcelona*



# New R&D Laboratory for Fire Protection



# Standardized testing for fire resistance




## Internal testing



### Screening tests in small-scale furnaces

- Plates 30x20 cm
- Formulation adjustment



### Indicative tests in medium scale furnaces

- Sections 1 meter
- DFT range
- Massivity range

## External testing



### Official fire tests at third party institute

- According to international standards

# Global approvals for cellulosic products


- BS 476-21 Middle East, UK, APAC
- EN 13381-8 Europe
- UL 263 America, Middle East
- GB 14907 China
- GOST 53295 Rusia
- AS1530.4 Australia
  
- Other
  - Singapore BS8202
  - Korea – KS1227





# Specification of Intumescent coating systems

# Fire protection coating system



## Primer

- Adhesion to substrate in cold state
- Anticorrosion protection
- Stickability of intumescent char formed during fire exposure

## Intumescent

- Provides thermal insulation in fire exposure
- Contribution to anticorrosion by barrier effect


## Top-coat

- Aesthetic function
- Sealer function to prevent early degradation and inactivation of intumescent layer
- Weathering resistance to end-use conditions

# Typical intumescent coating systems


## Medium/High corrosion category - Exterior areas up to C4 (ISO12944)

- |                                    |               |                     |
|------------------------------------|---------------|---------------------|
| ▪ Epoxy primer with Zinc phosphate | 1 x 100µm     | HEMPADUR 15570      |
| ▪ Intumescent Coating              | 1 x acc spec. | HEMPACORE ONE 43600 |
| ▪ Polyuretane topcoat              | 1 x 100µm     | HEMPATHANE 55610    |




## Low/Medium corrosion category – Interior/exterior areas up to C3 (ISO12944)

- |                                    |               |                       |
|------------------------------------|---------------|-----------------------|
| ▪ Epoxy primer with Zinc phosphate | 1 x 80µm      | HEMPADUR 15570        |
| ▪ Intumescent Coating              | 1 x acc spec. | HEMPACORE ONE 43600   |
| ▪ Acrylic Topcoat                  | 1 x 50µm      | HEMPATEX ENAMEL 56360 |



## Very low corrosion category - Interior areas up to C2 – indoor (ISO12944)

- |                                    |               |                     |
|------------------------------------|---------------|---------------------|
| ▪ Epoxy primer with Zinc phosphate | 1 x 80µm      | HEMPADUR 15570      |
| ▪ Intumescent Coating              | 1 x acc spec. | HEMPACORE ONE 43600 |




# Extension of Assessment report to systems

- Classification of Resistance to Fire by Third party evaluation – FR 30, 60, 90, 120 minutes
  - EN, BS, UL standards
  - Fire testing of 1 paint system: primer/intumescent with or without topcoat
- BS8202
- ETAG18-2 – European Technical Approval Guideline – EOTA (since year 2008)
- Work in progress to new standard prEN16623



# ETA – European Technical Assessment and CE marking

- According to ETAG018 Part 2 – Technical Guideline
- Issued by Notified Body – member of EOTA
- Fitness for end-use:
  - Resistance to fire (EN13381-8) – Loading tables
  - Reaction to fire (EN13501-1) – Smoke generation and flame spread
  - Primer compatibility - Substrates
  - Durability of systems in weathering exposure conditions
  - Slow heating exposure
  - Identification (fingerprint) of primers and topcoats



**Documento de Idoneidad Técnica Europeo** DITE 12/0581

Nombre comercial:	HEMPACORE ONE 43600 & HEMPACORE ONE PD 43601
Título del DITE:	Hempel AIS
Titular del DITE:	Lundtofte&Sivertsen 91
Holder of approval:	DNV-2000 Risk-Lundtofte Denmark
Area genérica y uso del producto de construcción:	Pinturas reactivas para la protección contra el fuego de elementos de acero
Element: type and use of construction product:	Reactive coatings for fire protection of steel elements
Valides:	de from 29.04.2013
Validty:	hasta to 16.01.2018
Plantas de fabricación:	Según anexo N custodiado por el ITeC
Manufacturing plants:	According to annex N kept by ITeC
El presente Documento de Idoneidad Técnica Europeo contiene:	47 páginas, incluyendo 1 anexo que forma parte del documento.
This European Technical Approval contains:	47 pages including 1 annex which form an integral part of the document.
Esta versión sustituye:	DITE 12/0581 válido de 17.01.2013 hasta 16.01.2018
This version replaces:	ETA 12/0581 valid from 17.01.2013 to 16.01.2018

**EOTA** Organización Europea para la Idoneidad Técnica  
European Organisation for Technical Approvals



**CE**

**CERTIFICADO DE CONFORMIDAD CE**

**1220-CPD-1320**

De acuerdo con la Directiva 90/100/CEE del Consejo de las Comunidades Europeas de 21 de diciembre de 1989, relativa a la aprobación de los dispositivos regios, reglamentarios y administrativos de los estados miembros sobre la Directiva de Productos de la Construcción (CPR), modificada por la Directiva 90/269/CEE del Consejo de las Comunidades Europeas de 29 de junio de 1990, en la vertida que el producto:

**Hempacore One 43600**

Pinturas reactivas para la protección contra el fuego de elementos de acero

Fabricado por **HEMPEL A/S**  
Lundtoftevej 150  
DK-7850 Lyngby  
Dinamarca

En la sociedad de **PINTURAS HEMPEL SAU**  
Carrer de Santarriol 108  
08017 Vilanova  
Barcelona (España)

Se certifica por el fabricante a un control de producción en fábrica y al ensayo posterior de los materiales tratados en fábrica de acuerdo con un plan de ensayo preestablecido que el organismo notificado ITeC ha tenido a salvo los ensayos iniciales de tipo de los característicos esenciales de producto, la inspección inicial de la fábrica y del control de producción en fábrica y que realiza el seguimiento posterior, la inspección y la verificación de los controles de producción en fábrica.

Este certificado indica que todos los dispositivos relativos a la evaluación de conformidad y caracterización de acuerdo con el DITE:

**DITE 12/0581**  
Válido desde 19/04/2013 hasta 16/01/2018

Se han aplicado los requisitos de marcado CE que se detallan en el anexo de este certificado. Para obtener información detallada en relación a los procedimientos del producto, se debe consultar el contenido del DITE mencionado anteriormente.

Este certificado ha emitido por primera vez el 12/02/2013, se vuelve permanente siempre que no se modifiquen significativamente las condiciones del DITE 12/0581, las condiciones de fabricación o el control de producción en fábrica.

Barcelona, 19 de febrero de 2013

**ITeC** Institut de Tecnologia de la Construcció de Catalunya

**ITeC** Institut de Tecnologia de la Construcció de Catalunya  
Artur M. Casas Torres  
Director General del ITeC

Para conocer la vigencia de este certificado consulte la página web de ITeC: [www.itec.cat](http://www.itec.cat)



# Guidelines for compatibility testing of primers only in Europe - ETAG18-2

- Only 1 primer from each primer family is subjected to testing (separate for each intumescent product)

Generic Primer Type	Maximum Approved Tested Thickness + (%)
Acrylic	50
Short/medium oil alkyd	50
Two component epoxy	50
Zinc rich epoxy (containing about 80% by mass of metallic zinc powder)	50
zinc silicate	50

- Substrates other than carbon steel must be tested with relevant primer
- Aim is to prove similar protection time than ref. primer used in initial type testing
- Fire tests at external lab on 2 panels per primer – 1000 microns DFT intumescent
- Multi-coat primer systems of more than one primer or more than one coat of the same primer shall be tested as one primer system
- A primer on top of a temporary blast primer (pre-construction) is not considered a multi-coat system

# Compatibility testing of primers – ETAG18-2



# Additional internal testing of primers



Good stickability steel-primer and primer-intumescent

Bad stickability: lack of adhesion steel-primer causing char detachment

# Exposure conditions – topcoat approval

- Intumescent coatings are sensitive to humidity
- Topcoat act as sealer to prevent moisture penetration and ensure long-life
- Testing in different end-use conditions is necessary
  
- ETAG describes the following environmental conditions:

Exposure	
Type X	Exterior
Type Y	Semi exposed
Type Z1	Interior high humidity
Type Z2	Interior

# Increased reliability & durability


## Exposure tests according to ETAG-018 Type X-conditions (outdoor conditions)

- Phase 1: **Spray QUV** (112 cycles in 28 days) of:
  - 5 hours of dry UV exposure at 50°C (± 3°C) with relative air humidity of 10% (± 5%)
  - 1 hour of water spray at 20°C (± 3°C)
  
- Phase 2: **Climatic chamber** (2 cycles as described in the below table where the coating is exposed to extreme temperature and humidity changes)






Day	6 hours	6 hours	6 hours	6 hours
1. + 2.	20°C ± 3°C 95% ± 5% rh	70°C ± 3°C 20% ± 5% rh	20°C ± 3°C 95% ± 5% rh	70°C ± 3°C 20% ± 5% rh
3. + 4.	20°C ± 3°C 95% ± 5% rh	30°C ± 3°C 40% ± 5% rh	40°C ± 3°C 95% ± 5% rh	30°C ± 3°C 40% ± 5% rh
5. + 6 + 7.	-20°C ± 0°C	40°C ± 3°C 95% ± 5% rh	-20°C ± 3°C	40°C ± 3°C 95% ± 5% rh

# Compatibility testing of topcoats – ETAG18-2



# Increased reliability & durability

- Results show superior durability under exterior conditions







Securing high  
quality



# Quality control

- Factory Production Control - production only in approved and certified factories
- Quality control of raw materials and finished product
- Control of changes
- Process controls
- Initial audit
- Continuous surveillance
- Voluntary adoption of “**Guidance to a quality control fire test regime for intumescent coatings**” prepared by the Intumescent Coatings Technical Committee (ICTC) of CEPE



# Quality assurance

## Testing required for

- Changes in production equipment/processes
- Change of formulation
- Change in raw material supply

Probability of effect on fire protection performance	Fire test level	Test to be performed
Certain	5	Loaded beam at maximum DFT according to EN 13381-8 at accredited laboratory
High	4	1 m specimens according to EN 13381-8 at accredited laboratory
Moderate	3	1 m specimens according to EN 13381-8 internally
Low	2	Insulating efficiency test according to Laboratory Instruction RD-142
Very low	1	Char expansion test according to Laboratory Instruction RD-141

# Wrap-up

- PFP of structural steel is a matter of safety
- Reliability and Durability of fire resistance coatings are essential – Only one chance to perform during lifetime of the building
- Third party certifications – Quality assurance
- Additional stringent internal test protocols



Thank you...